## CHAPEL HILL

## **Project Details**

## Overview

Site Description			
<b>Project Name</b>	Eastowne Redevelopment – Medical Office Building-1		
Address	100 Eastowne Drive 365,033 sq. ft. (8.3 acres) Office Park - UNC Health Care System		
<b>Property Description</b>			
Existing			
Orange County Parcel Identifier Numbers	9890-80-0195		
Existing Zoning	Office/Institutional-2 (OI-2)		
Proposed Zoning	Office/Institutional-3 (OI-3)		

Development Intensity					
Topic	Comment				
Use/Density (Sec 3.7)	Medical office and clinic use		$\odot$		
	Required (Eastowne Dr. only)	Proposed			
Dimensional	22' street setback	22' street setback			
Standards (Sec. 3.8)	8' interior setback	8' interior	$\odot$		
(,	9' solar setback no setbacks along US 15-501 (however 30' buffer) Height: 90 feet as measured from finished floor elevation				
Floor area (Sec. 3.8)	Maximum of 199,772 sq. ft.; (25,546 sq. ft. existing to remain);		$\bigcirc$		
( <u>Sec. 3.8</u> )	Proposed total 178,546 sq. ft.	(153,000 sq. ft. new)			
Modifications to Regulations (Sec. 4.5.6)	Landscape buffer; Building height; Resource Conservation District.				
Adequate Public Schools (Sec. 5.16)	Not applicable		N/A		
Inclusionary Zoning (Sec. 3.10)	Not applicable		N/A		
Landscape					
Buffer - North (Sec. 5.6.2)	10' Internal Type "B"		$\odot$		
Buffer – East (Sec. 5.6.2)	10' Internal Type "B"		$\odot$		
<b>Buffer – South</b> (Sec. 5.6.2)	30' External Type "D" (Modified)		М		
Buffer - West (Sec. 5.6.2) 20' External Type "C"		$\odot$			

Tree Canopy (Sec. 5.7)	Minimum 30% canopy	
Landscape Standards (Sec. 5.9.6)	Constructed to Town standards	
Environment		
Resource Conservation District (Sec. 3.6)	Proposing 18,836 sq. ft. of land disturbance. Disturbance associated with the accessible parking spaces to be permitted	
Erosion Control (Sec. 5.3.1)	More than 1 acre of land disturbance proposed; Performance bond required.	$\odot$
Steep Slopes (Sec. 5.3.2)	Not applicable	
Stormwater Management (Sec. 5.4)	Partially flowing to vegetated buffer around existing pond, partially tied-in to existing storm drainage system.	<b>⊘</b>
Land Disturbance	351,965 sq. ft. (includes off-site work)	
Impervious Surface	Existing: 183,032 sq. ft. (46% of net land area)	
(Sec. 3.8) Solid Waste &	Total proposed: 173,373 sq. ft. (42% of net land area)	
Recycling	Proposing private contractor to collect solid waste, recyclable cardboard, and mixed recycling	
Jordan Riparian Buffer (Sec. 5.18)	Proposing 9,793 sq. ft. of land disturbance within Jordan Buffer to remove existing structures and revegetate	
<b>Access and Circula</b>	tion	
Road Improvements (Sec. 5.8)	Curb and gutter	
Vehicular Access (Sec. 5.8)	Access on Eastowne Drive with secondary emergency access to US 15-501	(S)
Bicycle Improvements (Sec. 5.8)	10' multi-use path along Eastowne Drive frontage; installation of bike fix station;	<b>②</b>
Pedestrian Improvements (Sec. 5.8)	10' multi-use path along Eastowne Drive frontage; Accessible sidewalk route; Internal sidewalk connectivity; Installation of pedestrian crosswalk across US 15-501.	<b>⊘</b>
Road Improvements	<ul> <li>Eastowne Drive/SECU/US 15-501 intersection improvements to include:         <ul> <li>Left-turn from US 15-501 to Eastowne Drive extended to a minimum of 400 feet;</li> <li>Left-turn from Eastowne Drive to US 15-501 extended to a minimum of 300 feet;</li> </ul> </li> </ul>	
( <u>Sec. 5.9</u> )	<ul> <li>US 15-501/Eastowne Drive/Lakeview Drive intersection improvement to convert southbound approach to include dual left turn lanes with 300 feet of storage and a through/right-turn lane;</li> <li>A \$3,000 payment-in-lieu for optimizing signal timing at US 15-501 and Eastowne Drive/SECU driveway.</li> <li>Median at Eastowne Drive and Dobbins Road to be closed;</li> </ul>	
Vehicular Parking (Sec. 5.9)	1,169 spaces total, including 70 accessible spaces	$\odot$

Transit ( <u>Sec. 5.8</u> )	Bus shelter with pad, bench, shelter, "nextbus" sign, and refuse receptacle	
Bicycle Parking (Sec. 5.9)	26 total proposed spaces	<b>Ø</b>
Parking Lot Standards (Sec. 5.9)	Built to Town standards	
Technical		
Fire	Full fire flow study and report will be provided during the Final Plan phase	<b>Ø</b>
Site Improvements	New building and parking deck that are ADA compliant	$\odot$
Recreation Area (Sec. 5.5)	Not applicable	N/A
Lighting Plan (Sec. 5.11)	Town standard of 0.3 foot-candles at property line	$\odot$
Homeowners Association (Sec. 4.6)  Not applicable		N/A

## **Project Summary Legend**

Symbol	Meaning	Symbol	Meaning
$\odot$	Meets Requirements	NA	Not Applicable
М	Seeking Modification	С	Requires Council Endorsement