



January 22, 2019 - Minor Alteration Request

HILLSTONE CHAPEL HILL

1000 & 2000 Novus Lane Chapel Hill, North Carolina

PIN #'s: 9799-36-6631, 9799-36-7662, 9799-46-1235

JDAVIS > Architect / Land Planner / Landscape Architect

- Relocation of Gas Meters onto Exterior Building Elevations
- 2. Building 1 Transformer Design & Orientation





ISSUE:

PSNC originally approved the CDC & FDP approved locations for the gas meters within the building footprints. After construction began, PSNC rescinded this approval, stating they could not install or maintain meters within the building footprint.

PROPOSED SOLUTION:

Relocate meters to exterior building elevations accessible by PSNC and away from street views immediately adjacent to the site.








SUBJECT	SECTION	PAGE#
METER SET INSTALLATION STANDARDS	SU-205	4 of 63
TITLE	DATE	
FIELD INSTALLATION GUIDE	ISSUED	12/05/2008
	EFFECTIVE	01/02/2009

Standard Drawing A-425-7-1

Meter Info		
Model	Туре	
AL-425	3124	
R-415	3232	

ERT Programming		
Number of Dials	4 Dial	
Drive Rate	2 CF	
PCOMP	Non-Comp	
PCOMP	1.0000	
Value	1.0000	





Pressures	
Customer Delivery	7" WC
Metering Pressure	7" WC
Minimum Inlet	30 PSIG
Maximum Inlet	60 PSIG

Total Connected Load		
1 Appliance	251-425 CFH	
2 Appliances or more	314-531 CFH	

Notes	

SERVICE ROAD






DESIGN ALTERNATE 4: BLOCK PERIMETER AT BUILDING 1

Locations on building elevation identified by PSNC as adequate for meter relocation





EAST ELEVATION - BUILDING 1 FACING PEDESTRIAN CONNECTOR






ELEVATIONS - BUILDING 1 AT POOL COURTYARD









Proposed relocation of gas meter for CDC review/approval

WEST ELEVATION - BUILDING 2


2. Building 1 - Transformer Design & Orientation

ISSUE:


The original Building 1 design called for (2) transformers per the estimated electrical loads developed by the Engineer of Record for the projecet. Duke Energy is responsible for the final design of the site electrical service, which was not completed until AFTER construction began. The final Duke Energy Design requires (4) transformers which will require a larger pad footprint.

PROPOSED SOLUTION:


Locate the (4) transformers in the previously approved locations. This thereby maintains a location away from street views immediately adjacent to the site, yet still accessible to Duke Energy for maintenance.








DESIGN ALTERNATE 4: BLOCK PERIMETER AT BUILDING 1
ORIGINAL APPROVED PLAN LAYOUT



PROPOSED MODIFICATION TO TRANSFORMER LAYOUT



PROPOSED ADJUSTMENT TO LANDSCAPE SCREENING SURROUND TRANSFORMERS



BEFORE - AFTER LANDSCAPE ADJUSTMENTS